

Packaged Terminal Air Conditioner for Replacement

RSCM/A/B/C Series

Ice Air's RSCM/A/B/C Series Replacement and Retrofit units are high energy efficiency PTACs. Designed from the ground up for ultra-high efficiency, they incorporate advanced LEEDs features in a durable and user-friendly package.

Features:

- Ultra-high efficiency – EERs to 10.5
- Advanced tangential indoor blower provides balanced air flow
- Whisper quiet sound levels
- Standard programmable digital touchpad controls
- 5/2 or 7 day programming
- Heavy duty, commercial-grade construction throughout
- G90 galvanized steel construction, powder-coated drain and base pans
- Furniture-grade, powder-coated cabinetry



RSCM/A Replaces:

ClimateMaster 702, 703, 704
 Friedrich – 702, 703, 704
 Weil-McClain – 702, 703, 704
 Islandaire – CM
 Retroaire – RC/RH20

RSCM/B and RSCM/C Replaces:

ClimateMaster – 700 AD
 Friedrich – 700 AD
 Weil-McClain – 700 AD
 Islandaire – AD
 Retroaire – RC/RH20

SERIES MODEL #	5RSCM13	8RSCM13	8RSCM18
Cooling Capacity ¹ (BTU/h)	11,600	12,400	16,000
EER	8.5	9.0	8.2
Heating Capacity - Hot Water ² (BTU/h)	16,500	16,500	16,500
Heating Capacity - Steam ³ (BTU/h)	18,700	18,700	18,700
Electric Heating MAX (kW)	1.5	4.3	4.3
Voltage	115	208/230	208/230
Amperage	11.9	6.6	9.4
Watts	1,365	1,378	1,951
Airflow AC High Speed (CFM)	370	430	480
Weight Net/Ship (lbs)	117/133	124/138	141/157

SPECIFICATION NOTES:

1. Cooling mode performance ratings are in compliance with AHRI standard 310/380 and CSA standard 744.
2. BTUH @ 200 °F. E.W.T.; 65 °F. E.A.T. & 2 G.P.M. flow rate.
3. BTUH @ 2 PSIG STEAM & 65 °F. E.A.T.
4. Performance data based on R32 green refrigerant.

IMPORTANT: Additional voltages and alternate electric heat and heat pump options are available. For performance data and other available options please consult factory. Accessories are optional. Deviations from standard accessories may affect performance; louver requires 70% free area per original OEM specification; room enclosures must provide sufficient return air, free flowing supply air and must be properly sealed to prevent air recirculation; any non-standard components or accessories must be reviewed and approved by Ice Air or approved distributor.