

Packaged Terminal Air Conditioner for Replacement

RSEA Series

Ice Air's RSEA Series Replacement and Retrofit units are high energy efficiency PTACs. Designed from the ground up for ultra-high efficiency, they incorporate advanced LEEDs features in a durable and user-friendly package.

Features:

- Ultra-high efficiency – EERs to 9.4
- Advanced tangential indoor blower provides balanced air flow
- Whisper quiet sound levels
- Standard programmable digital touchpad controls
- 5/2 or 7 day programming
- Heavy duty, commercial-grade construction throughout
- G90 galvanized steel construction, powder-coated drain and base pans
- Furniture-grade, powder-coated cabinetry



Replaces:

McQuay – EA, ES, RS
 Remington – EA, ES, RS
 Singer – EA, ES, RS
 Islandaire – ED
 Retroaire – RC/RH35

SERIES MODEL #	5RSEA07	5RSEA09	5RSEA13	8RSEA09	8RSEA13	8RSEA18	7RSEA09	7RSEA13
COOLING CAPACITY*	7,250	9,000	12,100	9,300	12,150	16,300	9,000	12,100
EER	9.4	9.1	8.4	8.95	8.35	7.7	9.1	8.4
HEATING CAPACITY (HOT WATER)**	16,500	16,500	16,500	16,500	16,500	19,400	16,500	16,500
HEATING CAPACITY (STEAM)***	15,100	15,100	15,100	15,100	15,100	18,100	15,100	15,100
ELECTRIC HEATING MAX. (KW)	1.5	1.5	1.5	4.3	4.3	4.3	3.5	3.5
VOLTAGE	115	115	115	208/230	208/230	208/230	277	277
AMPERAGE	6.7	8.6	12.5	5.0	7.0	10.2	3.6	5.2
WATTS	771	989	1,440	1,039	1,455	2,117	989	1,440
CFM ROOM AIR HIGH	370	370	370	370	370	430	370	370
CFM ROOM AIR LOW	260	260	260	260	260	260	260	260
CFM OUTSIDE AIR	60	60	60	60	60	60	60	60
CFM X OUTSIDE AIR	110	110	110	110	110	110	110	110
WEIGHT NET/SHIP	120/136	120/136	120/136	120/136	120/136	130/146	120/136	120/136

SPECIFICATION NOTES:

1:* = BTUH @ 80°F. DB/67 °F. WB INDOORS; 95 °F. DB OUTDOORS.

2:** = BTUH @ 200 °F. E.W.T.; 65 °F. E.A.T. & 2 G.P.M. FLOW RATE.

3:*** = BTUH @ 2 PSIG STEAM & 65 °F. E.A.T.

IMPORTANT: Accessories are optional. Deviations from standard accessories may affect performance; lower requires 70% free area per original OEM specification; room enclosures must provide sufficient return air, free flowing supply air and must be properly sealed to prevent air recirculation; any non-standard components or accessories must be reviewed and approved by Ice Air or approved distributor.